

**Manufacturer's Name:** Delta Controls Inc.  
**Manufacturer's Address:** 17850 56<sup>th</sup> Avenue  
 Surrey, British Columbia, V3S 1C7  
 Canada  
**Telephone Number:** 604-574-9444

**Declares under our sole responsibility that the following product(s):**

**Product Name:** Sensor Hub 2.0  
**Model Numbers:** O3-HUB2, O3-HUB2-2xP  
**Product Options:** All

**Comply with the relevant European Union legislations:**

2014/30/EU Electromagnetic Compatibility (EMC) Directive  
 2014/53/EU Radio Equipment Directive (RED)  
 The product was tested in a typical configuration to check conformity with the EMC and RED directive.  
 2011/65/EU RoHS Directive  
 To our best knowledge, the product complies with the RoHS 2 Directive, which may or may not include exemptions. Restricted substance amounts, if present, are below the required limits as shown in Table 1, on next page.

**Conform to the following harmonised standards and technical specifications:**

**EMC**

EN 61000-6-3:2007/A1:2011/AC:2012	Generic Emission Standard Part 1: Light Industrial/Residential	
EN 55032:2012/AC:2013	Emission Requirements for Multimedia Equipment	
ANSI C63.4-2014	Methods of Radio-Noise Emissions Measurements	
EN 55032:2012/AC:2013	Radiated Emissions	Class B
EN 55032:2012/AC:2013	AC Mains Conducted Emissions	Class B
EN 61000-3-2:2014	Power Line Harmonics	Class A
EN 61000-3-3:2013	Power Line Fluctuations	$P_{st} < 1, P_{lt} < 0.65$
EN 61000-6-1:2007	Generic Immunity Standard Part 1: Light Industrial/Residential	
ETSI EN 301 489-1 v2.2.1	EMC for Radio Equipment and Services Part 1: Common Requirements	
EN 61000-4-2:2009	ESD Immunity	Criterion A
EN 61000-4-3:2006/A2:2010	RF Electromagnetic Field Immunity	Criterion A
EN 61000-4-4:2012	EFT/Burst Immunity	Criterion A/A
EN 61000-4-5:2014/A1:2017	Surge Transient Immunity	Criterion A/A
EN 61000-4-6:2014	Conducted Immunity	Criterion A
EN 61000-4-8:2010	Power Frequency Magnetic Field Immunity	Criterion A
EN 61000-4-11:2004/A1:2017	Voltage Dips / Interruptions	Criterion A/A/A/C

**RED**

ETSI EN 301 489-1 v2.2.1	EMC for Radio Equipment and Services Part 1: Common Requirements
ETSI EN 300 328 v2.2.2	Harmonised Standard to test Transmitter unwanted emissions

Agustin Castellanos  
 Chief Operating Officer  
 December 27, 2020

**Table 1. European RoHS 2 Restricted Substances:**

Substance	Max. Allowable Limit (2011/65/EU – RoHS)	Exceeding (Yes/No)
Lead (Pb)	0.1% (weight) / 1000 ppm	No
Mercury (Hg)	0.1% (weight) / 1000 ppm	No
Cadmium (Cd)	0.01% (weight) / 100 ppm	No
Hexavalent Chromium (Cr6+)	0.1% (weight) / 1000 ppm	No
Polybrominated Biphenyls (PBB)	0.1% (weight) / 1000 ppm	No
Polybrominated Diphenyl Ethers (PBDE)	0.1% (weight) / 1000 ppm	No

## FCC, ISED Canada, UL and CSA Compliance Information

### FCC Compliance Information:

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules and ICES-003. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

Caution: Changes or modifications to this equipment, not expressly approved by the manufacturer could void the user's authority to operate the equipment.

### ISED Canada Compliance Statement:

ICES-003 Issue 6

CAN ICES-3 (B)/NMB-3(B)

### UL and CSA Compliance Information:



This Product confirms to the following UL and CSA requirements:

UL 916: Energy Management Equipment

CAN/CSA C22.2 No. 205: Signal Equipment – Consumer and Commercial Equipment