

FCC Compliance Information

This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense.

Industry Canada Compliance Statement

ICES-003 This Class A digital apparatus meets all requirements of the Canadian Interference-Causing Equipment Regulations

Cet appareil numérique de la Classe A Respecte toutes les exigences du Règlement sur le matériel brouiller du Canada.

UL Compliance Information



This product conforms to the following UL requirements:

UL916 (C22.2 No. 205-M1983): Energy Management (Signal) Equipment

CE - DECLARATION OF CONFORMITY

according to ISO/IEC Guide 22 and EN 45014

Manufacturer's Name: Delta Controls
Manufacturer's Address: 17850 56th Avenue
Surrey, British Columbia
Canada
V3S 1C7

declares that the product (s):

Product Name: RS-232/485 Converter
Model Numbers: CON-768
Product Options: All

conforms to the following Product Specifications:

EMC:

EN 55022:1998	Radiated and Conducted Emissions	Class A
EN 50082-1:1997	Generic Immunity Standard	
EN 61000-3-2:1999	Harmonic Current Emissions	Class A
EN 61000-3-3:1998	Voltage Fluctuations and Flicker	
EN 61000-4-2:1995 + A1:1998	ESD Immunity	Level B
EN 61000-4-3:1996	RF Electromagnetic Field Immunity	Level A
ENV 50204:1995	RF Electromagnetic Field Immunity (Keyed)	Level A
EN 61000-4-4:1995	EFT/Burst Immunity	Level B
EN 61000-4-5:1995	Surge Immunity	Level B
EN 61000-4-6:1996	Conducted RF Disturbances Immunity	Level A
EN 61000-4-11:1994	Voltage Dips / Interruptions	Level B/C

Supplementary Information:

The product(s) herewith comply with the requirements of the EMC Directive 89/336/EEC. The product(s) were tested in a typical configuration.

Date: October 21, 2002
Lee Dickson
Quality Assurance Manager



